



Typical control signal types ran to control room include :

- 4-20ma DC analog current loops and
- 24-48 VDC digital signals

**Poured Conduit Seal-Off  
KILLARK # EY-1 or EY-2  
or equivalent**

**To be used in conjunction with  
Killark Series SC Sealing Compound  
and Killark Series PF Packing Fiber  
or equivalent**

CONTROL ROOM  
SAFE AREA

DESIGNER <b>EEE</b>	INITIAL DATE <b>11/26/01</b>	DUE <b>8-29</b>	SHEET <b>1</b>	<div>INTERCAT</div> <div>SAVANNAH, GEORGIA</div>	<div>IMS TO</div> <div>CONTROL ROOM</div>